



**City of Pompano Beach, Purchasing Division  
1190 N.E. 3rd Avenue, Building C  
Pompano Beach, Florida, 33060**

March 6, 2012

**ADDENDUM #1, BID H-19-12  
TENNIS CENTER RENOVATIONS**

To Whom It May Concern,

Please review the next page for changes/clarifications/answers from the design consultant.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 14 of the Bid.

Very truly yours,

Leeta Hardin  
General Services Director

enclosure

cc: website  
file

## ADDENDUM #1

**TO:** ALL BIDDERS  
**FROM:** Walters Zackria Associates  
**SUBJECT:** Project: City of Pompano Beach Community Park Tennis Center Renovations  
CIP #: 11-125  
**DATE:** March 06, 2012

This Addendum is hereby made part of the plans and specifications and shall be included with all contract documents. The following items have been revised and will take precedence over previously issued plans and specifications.

1. The new Fence structural members shall be as follows:  
**Line Posts:** 3-1/2" O.D. Vinyl coated SS 40 galvanized steel pipe;  
**Corner Posts:** 4" O.D. Vinyl coated SS 40 galvanized steel pipe;  
**Top, Mid, & Bottom Rails:** 2-3/8" O.D. Vinyl coated SS 40 galvanized steel pipe.  
All Gate structural members shall be as stated in the Construction Documents.  
Contractor shall bid using the information stated above.  
Reduction in member size and spacing will not be permitted.
2. The quantities and model numbers for the Canopy Shades shall be:  
(3) 10'-0" x 20'-0" x 8'-6" high **TC 10208.5 by Shade Systems** or approved equal;  
(1) 10'-0" x 30'-0" x 8'-6" high **TC 10308.5 by Shade Systems** or approved equal;  
(5) 10'-0" x 20'-0" x 8'-6" high **SW 10208 by Shade Systems** or approved equal.
3. The Tennis Court Lighting shall be revised as follows: The average constant light levels shall be maintained at 60 foot-candles. The **Warranty and Guarantee** shall be: Manufacturer to supply a signed 5-Year Warranty covering the Light Fixture Housing, including the paint. In addition, a 3-Year Warranty covering all Lamps, Ballasts, and Capacitors shall be supplied.
4. The Fence Structure and Canopy Shades shall be designed in accordance with the FBC 2010 and ASCE 7-10. The following design criteria shall be used: Category I, Exposure C, and wind speed of 156 MPH.
5. Contractor may cut line posts 6" below grade and bury the remaining posts and foundations in place where they are not in conflict with the replacement fence and foundation. Where in conflict, remove fence post and foundation in its entirety.