



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

May 2, 2012

ADDENDUM #3, RFP H-48-11 STEP 2

To Whom It May Concern,

Please review the following question and answer regarding this solicitation:

1. Question - Article 3.14 of the Design Criteria states that "the DB shall provide R-19 insulation for the walls for conditioned spaces." In order to provide said value, the result will be a loss of approximately five inches per wall of interior function floor space and an excess over the requirement of the Florida Energy Code or what may benefit the building from a LEED perspective. Could the exterior wall R-value be reduced to comply with code requirements even though it will be less than 19?
1. Answer - The reference to specific R values is only for the Storage Building if it is designed as a metal building. Since the Storage Building will not have conditioned space, only the second sentence regarding insulation for non-conditioned space will be relevant.

The Administration Building shall be designed to meet the 2010 edition of the Florida Building Code-Energy Conservation Volume. Additional insulation and energy saving measures may be necessary depending on the approach to LEED Certification.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in your proposal response.

Very truly yours,

Leeta Hardin
General Services Director

cc: website
file