



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

August 23, 2012

**ADDENDUM #5, BID H-59-12
SUPPLY LIGHTS FOR OCEANSIDE PARKING LOT**

To Whom It May Concern,

The deadline for submission of sealed bids is extended to 2:00 p.m., August 28, 2012.

This addendum is to clarify the bid specifications and performance requirements.

The Phillips light specified meets illumination and operation requirements and any light proposed as an equal must perform as required.

The light should operate at full intensity during night time hours.

The City's code requires the recommendation of the IES Lighting handbook; one (1) foot candle required for self-parking areas. The illumination level of one (1) foot candle remains unchanged.

The City has no specific wattage requirements. Bidders must determine the best wattage of light fixture, solar panel and battery capacity to meet the required lighting level.

For Bidders proposing an alternate to the Philips light specified, provide lighting plan and adequate solar LED lighting unit, mounting hardware and pole for the parking lot layout (layout previously provided by the City) to meet illumination levels of one (1) foot candle at parking lot surface. Lighting must not be visible from the adjacent beach, east of the parking lot. The awarded supplier must provide the necessary installation instructions to include bolt template for concrete footing for pole for installation by City forces or others.

No further technical specification questions will be accepted. The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 13 of the bid.

Very truly yours,

Leeta Hardin
General Services Director

cc: website
file