



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

June 28, 2012

**ADDENDUM #2, BID T-49-12
TEMPORARY EMERGENCY POWER INFRASTRUCTURE FOR CITY HALL**

To Whom It May Concern,

Please review the following questions submitted by potential bidders, and answers from the City.

Question 1: What license does the prime need to hold? Can the prime be a GC with a sub having an electrical license?

Answer 1: It is the preference of the City that the Prime Contractor be a licensed Electrical Contractor.

Question 2: General notes call for the contractor to be responsible for supplying power during shutdowns. Will the City of Pompano Beach entertain supplying a temporary generator/ fuel for this?

Answer 2: A line item (#44) for the supply of a fully fueled temporary generator for all the required testing of the system has been added to the bid proposal sheet. A revised proposal sheet will be available on our website at www.mypompanobeach.org.

Question 3: Will there be a dedicated staging area as there is no indication of such an area on the plans?

Answer 3: There are no areas that can be so designated at this time. The selected Contractor is encouraged to take only the material required to complete the day's work to the site.

Question 4: The scope consists of cutting through pavement at the entrance / exit, and the drive thru for the installation of the duct bank. Will there be scheduled days/times for this work?

Answer 4: The contractor will be responsible for MOT through the entrance to the parking lot on SW 2nd Street when the duct bank across the entrance /exit is being installed. The installation of the duct bank will be scheduled to cause minimum impact to the drive-thru teller during construction. A drawing of the parking lot will be available on our website at www.mypompanobeach.org.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is 2:00 p.m. (local), July 11, 2012.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 14 of the bid.

Sincerely,

Otis J. Thomas
Purchasing Agent

cc: website
file