



Florida's Warmest Welcome

**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

July 11, 2013

**ADDENDUM #1, BID H-44-13
PVC Fittings (Utility)**

To Whom It May Concern,

Please review the following questions and City responses regarding the Request for Proposals solicitation.

1. Question: Can you please clarify the items on this Bid. Are the items requested SDR35, SDR26, or are they for C900 pipe?

Response: Bid Items 1-6 SDR 35; Bid Items 7 and 8 will fit both SDR 35 and SDR 26. Items to be used in the wastewater transmission system.

2. Question: Please clarify if line 7 is a 4"x4" as written or a 4"x3" per the part number listed.

Response: Item required is 4"x4". The description for Bid Item 7 is corrected to read: 4" PVC to 4" PVC Coupling Fernco #1056-44, Indiana Seal, or equal.

Bidders should acknowledge receipt of this Addendum in the area provided on the Bid Proposal Signature page.

Very truly yours,

Leeta Hardin
General Services Director

cc: website
file