



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

November 21, 2012

ADDENDUM #2, BID T-10-13

**PUBLIC SAFETY COMPLEX EXTERIOR IMPROVEMENTS AND EMERGENCY
GENERATOR INSTALLATION**

To Whom It May Concern,

No further technical specification questions will be accepted for this project.

Please review the following questions submitted by potential bidders, and answers from the City.

Q1: What are the sizes and approved manufactures of the fuel tank and day tank for the generator?

A1:

- Fuel Tank is 8,000 gallons
- Day Tank is 400 gallons
- Fuel Tank Basis-of-Design Product: Subject to compliance with project requirements, provide Convault or a comparable product.
- Day Tank Basis-of-Design Product: Subject to compliance with project requirements, provide Simplex or a comparable product.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is 2:00 p.m. (local), November 28, 2012.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 15 of the bid.

Sincerely,

Otis J. Thomas
Purchasing Agent

cc: website
file