



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

December 3, 2012

**ADDENDUM #1, BID T-13-13
CARTRIDGE FILTERS**

To Whom It May Concern,

Please review the questions submitted by potential bidders, and answers from the City.

Question #1: Global Filter GWTB series cartridge does not require a polypropylene core, is a polypropylene core required?

Answer #1: Yes, for rigidity and to guard against breakage. Our filter vessels do not have a support in the middle, so the filters tend to sag in use. Too much filter sagging leads to them pulling out or bending/breaking.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is 2:00 p.m. (local), December 17, 2012.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 12 of the bid.

Sincerely,

Otis J. Thomas
Purchasing Agent

cc: website
file