



**City of Pompano Beach, Purchasing Division  
1190 N.E. 3rd Avenue, Building C  
Pompano Beach, Florida, 33060**

April 10, 2013

**ADDENDUM #2, BID T-29-13**

**SIDEWALK REPLACEMENT AND INSTALLATION**

To Whom It May Concern,

Please review the following questions submitted by potential bidders, and answers from the City.

**Q1:** I assume the specific survey work related to line item No.9 is the following: "Stake the centerline of the road right-of-way @ 100' intervals for establishment of the right-of-way lines." Is the City is going to provide Title Work pertaining to the street or streets in question; this will shed a little more light into the true requirements and cost of line item No.9.

**A1:** The City can provide right of way maps pertaining to the streets, or the street in question.

**Q2:** Can rising ring be used on the manholes?

**A2:** Yes up to (2) two inches, according to DOT standards.

**Q3:** Are there any manholes in the road ways?

**A3:** Yes.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is 2:00 p.m. (local), April 23, 2013.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 15 of the bid.

Sincerely,

Otis J. Thomas  
Purchasing Agent

cc: website  
file