



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

March 31, 2014

ADDENDUM #2, BID E-29-14

Water Treatment Plant Fuel Tank Replacement

To Whom It May Concern,

Please review the following question submitted by potential bidders, and answers from the City.

Q1: Page G-1.0 shows - New Modern Welding "Fireguard" 2,000 gallon DW AST. Equipment summary lists the tank manufacturer as Metal Products. Specifications section 01630-1.03 C says there is no option and no substitutions will be allowed. Drawing shows a rectangular tank, is a cylindrical tank an option. Please clarify.

Response: The tank shall meet UL 2085, UL 142, NFPA30 & 40A, STI F941. The reason for no substitution is that what is shown in the plans is what BC Environmental has approved; therefore, any changes need to be submitted to them. The cylindrical tank may be used, if the successful bidder is willing to pay the re-permitting and for City's time to change to his/her preferred equipment. The City does have a permit based on the existing plans.

Addendum #2 is posted on the City's website: <http://www.pompanobeachfl.gov>. Bidders must submit their bid with the revised information. Acknowledge receipt of this Addendum in the area provided on Page 14 of the bid.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), April 8, 2014.**

The remainder of the solicitation is unchanged at this time.

Sincerely,

Jeff English
Purchasing Agent

cc: website
file