City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060

April 3, 2014

ADDENDUM #3, BID E-29-14

Water Treatment Plant Fuel Tank Replacement

To Whom It May Concern,

Please review the following question submitted by potential bidders, and answers from the City.

Q1: I reviewed the published Addendum 2 and the Tank Drawings, and it appears that the tank is a Cylindrical Tank and not a Rectangular Tank as shown in Drawing G-1.0. The plan view will be rectangular for a cylindrical tank. Therefore, you may wish to clarify the response after checking with the Engineer of Record.

As long as the Tank meets UL-2085 Fireguard Specifications, it will be considered an equal and does not necessarily have to be obtained from any specific manufacturer. I have attached Highland Tank UL-2085 Fireguard Tank brochure for reference.

Response: Correct, as long as the tank meets UL 2085, UL 142, NFPA 30 & 40A, STI F941 and it is a "FIREGUARD" tank is acceptable as per our last response. The tank must also match the listed EQ# on the approved FDEP equipment list. The equipment list also includes other tank and fuel system components. An equipment list with the FDEP EQ# for this job is shown on drawing G-1.0. All equipment to be provided must meet FDEP EQ#. The tank manufacturers could be Metal Products, Modern Welding, Highland Tank, or any other that has an FDEP EQ# that can match what the City's job calls for. The dimensions shown on drawing G 1.0 are the 70" diameter of a cylindrical tank.

Addendum #3 is posted on the City's website: http://www.pompanobeachfl.gov. Bidders must submit their bid with the revised information. Acknowledge receipt of this Addendum in the area provided on Page 14 of the bid.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), April 8, 2014.**

The remainder of the solicitation is unchanged at this time.

Sincerely,

Jeff English

Purchasing Agent

cc: website
file