



City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060

May 23, 2014

ADDENDUM #1, BID E-47-14

Parts for Harbor Island Reuse Water Main

To Whom It May Concern,

Please review the following question submitted by potential bidders, and answers from the City.

Q1: Can we provide an equal manufacturer for the material below:

1. 4" MJ Bell Restraints PVC - **EBBA Iron Series1500** (Qty 12)
2. 4" x 1" Tapping Saddles, **Ford FC202-480-CC1**, DBL Strap, S/S (for PVC) (Qty 90).

Response:

1. The Bell Restraints must be EBBA Iron Series 1500.
2. Subject to approval as equivalent, the tapping saddles can be an "equal" if the straps are SS for PVC.

Addendum #1 is posted on the City's website: <http://www.pompanobeachfl.gov>. Bidders must submit their bid with the revised information. Acknowledge receipt of this Addendum in the area provided on Page 14 of the bid.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), June 2, 2014.**

The remainder of the solicitation is unchanged at this time.

Sincerely,

Jeff English
Purchasing Agent

cc: website
file