



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

October 6, 2014

ADDENDUM #2, BID E-73-14

Public Safety Complex Fire Alarm System

To Whom It May Concern,

Please review the following question submitted by potential bidders, and the answer from the City.

Q1: Request for bid Fire alarm system is based on Notifier panel.

This panel is part of proprietary system. Only limited dealers are permitted this panel. We use Fire-Lite - sister "HONEYWELL" company, with the same qualifications and is open to all fire alarm installers, more competition, lower price and more availability.

Response: Available manufacturers offering products that may be incorporated into the work include, but are not limited to, the following:

1. Faraday.
2. Fire-Lite Alarms.
3. GAMEWELL.
4. Notifier.
5. Siemens Industry, Inc.; Fire Safety Division.
6. Silent Knight.

Q2: On the plans legend it refers to the Fire Alarm Control Panel as a Notifier NFS-320 Fire Alarm Control Panel. However, on the riser diagram it indicates an NFS 2-3030. Which panel is the correct one?

Response: Per new Sheet FA-3.1: Changed FACP panel to a NSF-320 to match the legend.

Also the following changes have been made:

Sheet FA-2.2: added heat detectors in the main electrical room, chiller room. Added note #3 for monitoring of new PIV.

New piping and conduit shall be routed in the space above the jail ceiling and in chases.

The fire alarm control panel is changed per the addendum.

Please replace page 17 of your bid document with the attached corrections. The bid document has also been modified with the replacement page.

Note: Documents in the "Plans" section have been changed. Please see posting.

Addendum #2 is posted on the City's website: <http://www.pompanobeachfl.gov>. Bidders must submit their bid with the revised information. Acknowledge receipt of this Addendum in the area provided on Page 15 of the bid.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), October 15, 2014.**

The remainder of the solicitation is unchanged at this time.

Sincerely,

A handwritten signature in black ink, appearing to read "Jeff English", written in a cursive style.

Jeff English
Purchasing Agent

cc: website
file

Item	Description	Quantity	Unit	Unit Price	Amount
1	Provide new fire alarm system	1	LS		
2	Additional annunciation device	1	EA		
3	Additional detection device	1	EA		
4	Remove existing fire alarm system	1	LS		
5	Remove/replace ceiling tiles	50	EA		
6	Remove/replace hard ceilings **	2500	SqFt		\$15,000.00
7	Permit Fees *	1	LS		\$2,500.00
8	Indemnification	1	LS		\$10.00
	GRAND TOTAL				
*	The contractor shall pay all permit fees. The City will reimburse the contractor the fees.				
**	The contractor shall itemize the amount of removal and repair. The contractor shall include additional costs if greater than the amount listed.				

8. The above includes all the necessary excavation, backfill, grading, restoration, and removal of materials attendant upon the construction of the work, complete in place, and the disposal of all excess materials, and the final cleaning up of the work.

DATE _____ BIDDER: _____
(Corporation Name) (Partnership Name) (Trade Name)

BY: _____
Name & Title of Signer

Manual Signature

Company Name: _____

Company Address: _____

_____ (Zip) _____

Telephone #: (_____) _____

Facsimile #: (_____) _____

Federal I.D. # _____

State of Florida Contractor's license # _____

Broward County Certificate of Competency #: _____

Expiration Date: _____

9. At the preconstruction conference, the BIDDER shall submit a complete detailed schedule of shop drawing submittals which will show lead time for:
Date of Planned submittal.