



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

November 15, 2013

ADDENDUM #1, BID H-05-14

WATER TREATMENT PLANT FUEL TANK REPLACEMENT

To Whom It May Concern,

No further technical specification questions will be accepted for this project.

Please review the following questions submitted by potential bidders, and answers from the City.

Q1: On the plans page G-11 it states on the 2000 gallon fire guard AST and foundation layout item # 14 1" schedule 40 galvanized steel above grade for piping. Are you sure you want to use galvanized piping with diesel fuel even it has a chemical reaction with the pipe?

Response: Piping shall be black iron, black steel or gs steel that meets API5L. We specified gs and have used it in many above ground installations without any corrosion issues (Zinc being the main concern).

Q2: On the plans page G-30 it states Veeder-Root TLS-300 aboveground storage tank monitoring system. This model has been discontinued do you want us to quote a TLS-450 system?

Response: Veeder-Root still makes the TLS 300. I did get the answer from the VR representative.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), November 20, 2013.**

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 15 of the bid.

Sincerely,

Otis J. Thomas
Interim General Services Director

cc: website, file