City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060

November 21, 2013

ADDENDUM #3, BID H-05-14

WATER TREATMENT PLANT FUEL TANK REPLACEMENT

To Whom It May Concern,

Please review the following additions for this solicitation.

The removal and disposal of the Blue Belle engine exhaust piping insulation and replacing it with new insulation. The existing insulation does not contain asbestos in accordance with the test results conducted by the City on May 21, 2013.

The installation of a new muffler and associated connecting exhaust piping to be connected to the existing exhaust pipe outlet flange on the outside west wall of the high service pump room. The muffler's make and model will be provided by the City at a later date. Allowance for this this item is $25,000.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), November 22, 2013.**

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 14 of the bid.

Sincerely,

Otis J. Thomas
Interim General Services Director

cc: website, file