



City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060

May 14, 2015

ADDENDUM #1, RFP E-37-15


**CAST IN PLACE REPLACEABLE TACTILE / DETECTABLE WARNING SURFACE
TILES**

To Whom It May Concern,

Please review the following question submitted by a potential proposer, and the response from the City.

Q1: I would like clarification on the size of the second ADA pad on page 11. The normal sizes for these pads are 24 x 36. Is there a chance this was typed in error?

Response: There was no typographical error. The 24" X 33.25" dimensions stated in the specifications are accurate. See the following diagram for clarification.



Addendum #1 is posted on the City's website: <http://www.pompanobeachfl.gov>. Proposers must submit their proposal with the revised information. Acknowledge receipt of this Addendum in the area provided on Page 12 of the Bid document.

The deadline for acceptance of sealed proposals in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), May 28, 2015.**

Addendum #1, E-37-15

The remainder of the solicitation is unchanged at this time.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeff English". The signature is written in a cursive style with a large initial "J".

Jeff English
Purchasing Agent

cc: website
file