



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

May 21, 2015

**ADDENDUM #2, Bid L-22-15
WATER TREATMENT PLANT ELECTRICAL MASTER PLAN PHASE II IMPROVEMENTS**

To Whom It May Concern,

Please review the following questions submitted by potential bidders, and answers from the City.

Q1: Please clarify whether motors will need to meet IEEE841 specifications.

Response: Yes, per spec section 16222-1.02-E-4.

Q2: Will Motors be installed in a Class 1 Hazardous Environment?

Response: No, the motor environment will be indoor, humid and non-conditioned space.

Addendum #2 is posted on the City's website: <http://www.pompanobeachfl.gov>. Acknowledge receipt of this Addendum in the area provided on page 14 of the bid.

The deadline for acceptance of bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), May 27, 2015.**

The remainder of the solicitation is unchanged at this time.

Sincerely,

Cassandra LeMasurier, Purchasing Supervisor

cc: website
file