



REUSE INSPECTION FORM

Customer Address: _____ **Verificator Date/Time:** _____ **Name/Company** _____

Permit number: _____

The following items were inspected as required by the reuse connection contract, City Standards and Florida Regulations.

Item #		YES NO NA
1	All plastic reuse water piping, pipelines, valves, outlets, manifolds and other appurtenances continuously/consistently color-coded Pantone Purple 522C, or otherwise marked (i.e. meter box) to differentiate reuse water from other water (Rule 62-610.469(7)(f)).	YES NO NA
2	New purple piping was installed from the meter to the irrigation control valve using Pantone 522C irrigation pipe.	YES NO NA
3	Hose bibs or hand operated systems connected to the reuse system are visible from the street, locked and clearly labeled.	YES NO NA
4	An approved backflow preventer is installed on the potable water service (Rule 62-555.360)	YES NO NA
5	Hose bibb vacuum breaker installed on all potable hose faucets.	YES NO NA
6	The piping is free of cross-connection between the potable water system and reuse system as demonstrated by turning on sprinkler system (before connecting reuse) and testing all faucets, toilets and water connected fixtures (hot & cold sides) within the home and outside the home (boat docks) to make sure water is available.	YES NO NA
7	Sprinklers are supplied only by reuse water, with no connections to the potable water system ground water or canal (Rule 62-610.476(2)(b)).	YES NO NA
8	The top of the reuse water line is installed at least 12 inches below the bottom of the potable water line (Rule 62-610.469(7)(c)).	YES NO NA

Comments: _____

Signature _____ Date _____

Plumbing License # _____

Leave completed and signed form in the permit bag on-site for the Plumbing Inspector