



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

January 9, 2015

ADDENDUM #3, BID T-15-15

Furnish and Install Lime Softening Gear Box Unit

To Whom It May Concern,

Please review the following changes/additions to Bid T-15-15, Furnish and Install Lime Softening Gear Box Unit.

Changes/additions to the technical specifications:

1. Section 11220 – Replacement of Lime Softening Unit Drive, page 89: CHANGE the title of Section 2.05 as follows:

“2.05 LOCAL CONTROL PANEL (FIELD RELAY PANEL)”

2. Section 11220 – Replacement of Lime Softening Unit Drive, page 89, paragraph 2.05, A., 1: CHANGE the first sentence to read as follows:

“1. Furnish and install a new control panel (field relay panel) with the replacement drive unit...”

3. Section 11220 – Replacement of Lime Softening Unit Drive, page 89, paragraph 2.05, A: ADD the following after item number 3:

“The new panel shall be located at or near the location of the existing field relay panel, adjacent to the gearbox. The new field relay panel shall provide dry relay contacts for low gearbox oil level, high oil temperature, low oil pressure, and high motor temperature. The gearbox shall be furnished with the required level, pressure, and temperature sensing devices. Devices shall be as recommended by the gearbox manufacturer. Wiring from the field relay panel to the main control panel is existing to remain. Contractor shall test and verify wiring terminations.”

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), JANUARY 28, 2015.**

The remainder of the solicitation is unchanged at this time.

Sincerely,



Otis J. Thomas
General Services Director

cc: website
file