



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

May 11, 2016

ADDENDUM #2, Bid E-31-16

SANITARY SEWER MANHOLE REHABILITATION

To Whom It May Concern,

Please review the following inquiry submitted by potential bidders, and the response from the City.

Q1: When checking the bid, we noticed that Page 77 paragraph 3.04.B indicates the liner should be a minimum of 1-1/2 inches. We are just double checking the thickness as it is thicker than normal for a manhole.

Response: Please change minimum thickness language on page 77 paragraph 3.04.B from 1-1/2" to 1/2".

Addendum #2 is posted on the City's website:

<http://pompanobeachfl.gov/index.php/pages/purchasing/purchasing>. Bidders must submit their bid with the revised information. Acknowledge receipt of this addendum according in the section provided on Page 14 of the Bid document.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), May 16, 2016**. The remainder of the solicitation is unchanged at this time.

Sincerely,

Jeff English
Purchasing Agent

cc: website
file