



**City of Pompano Beach, Purchasing Division  
1190 N.E. 3rd Avenue, Building C  
Pompano Beach, Florida, 33060**

May 6, 2016

ADDENDUM #1, Bid E-36-16

**REPAINTING OF WATER TREATMENT PLANT STORAGE TANKS**

To Whom It May Concern,

Please review the following questions submitted by potential proposers, and answers from the City.

**Q1:** Drawings provided are difficult to read can you confirm the dimensions of each tank?

**Response:** The Water treatment plant tanks are 180 feet inside diameter, 26 feet tall. The reuse treatment plant tanks are 70 feet inside radius, 34 feet tall and 50 feet radius, 34 feet tall.

**Q2:** Are the 2 documents on the web site the complete bid package and are inclusive of all bid requirements?

**Response:** There are three (3) posted documents: The solicitation document and two attachments.

**Q3:** Do you have current inspection reports available for each tank?

**Response:** Painting is only for the exterior so the inspection report is not needed.

Please review the following changes to this solicitation.

**A Mandatory Pre-Bid Conference will be held on May 10, 2016 at 10:30 a.m. (local) in the Engineering Large Conference Room, 1201 N. E. 5th Avenue, Pompano Beach, Florida 33060. Bids will not be accepted from firms that do not attend the pre-bid conference.**

Replace page three of the solicitation document with the attached.

Addendum #1 is posted on the City's website:  
<http://pompanobeachfl.gov/index.php/pages/purchasing/purchasing>. Bidders must submit their bid with the revised information. Acknowledge receipt of this addendum in the section provided on Page 16 of the Bid document.

The deadline for acceptance of sealed bids in the Purchasing Office, 1190 N.E. 3<sup>rd</sup> Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), June 8, 2016.** The remainder of the solicitation is unchanged at this time.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jeff English".

Jeff English  
Purchasing Agent

cc: website  
file

## INVITATION TO BID

Sealed Proposals for **Bid E-36-16, Repainting of Water Treatment Plant Storage Tanks** addressed to the City of Pompano Beach, Purchasing Office, 1190 N.E. 3rd Avenue, Building C (front) Pompano Beach, Florida 33060, will be received until **2:00 p.m. (local), on June 8, 2016** and will be publicly opened and read aloud. Any bids received after the time and date will not be considered.

**A Mandatory Pre-Bid Conference will be held on May 10, 2016 at 10:30 a.m. (local) in the Engineering Large Conference Room, 1201 N. E. 5th Avenue, Pompano Beach, Florida 33060. Bids will not be accepted from firms that do not attend the pre-bid conference.**

On March 23, 2010, the City Commission approved a Resolution establishing a Local Business Program, a policy to increase the participation of City of Pompano Beach businesses in the City's procurement process. The City has set a 10% voluntary Local Business participation Goal for this project. Local Business Program Forms are located in this bid/contract document, and all bidders must return the Local Business forms in order to be considered for bid evaluation purposes.

The City has set a 10% voluntary Small Business Enterprise Goal for this project. SBE Forms are located in this bid/contract document, and all bidders must return the SBE forms in order to be considered for bid evaluation purposes.

The project consists of furnishing all labor, equipment, tools, and materials for the Repainting of the Water Storage Tanks at the Pompano Beach Water Treatment and Reuse Water Treatment Plants, according to attachments: "Storage Tank Plans," and "Tank Coating Specs," and as specified herein. Both five million-gallon storage tanks at the Water Treatment Plant are located 1205 N.E. 5<sup>th</sup> Avenue, Pompano Beach, 33060. The four million and the two million-gallon storage tanks at the Reuse Water Treatment Plant are located at 1799 N. Federal Highway, Pompano Beach, 33060.

Bid documents may be obtained at no charge from the City of Pompano Beach website [www.pompanobeachfl.gov](http://www.pompanobeachfl.gov).

Each proposal must be submitted on the prescribed form and accompanied by a certified check or bid bond executed on the prescribed form, payable to the City of Pompano Beach, Florida, in an amount not less than 5 percent (5%) of the amount bid. The bid form must be filled in completely and accurately, particularly as it pertains to alternate bid items.

The successful Bidder will be required to furnish the necessary additional bond(s) for the faithful performance of the Contract Documents. All bid bonds, contract bonds, insurance contracts and certificates of insurance shall be either executed by or countersigned by a licensed resident agent of the surety or insurance company having his place of business in the State of Florida, and in all ways complying with the insurance laws of the State of Florida. Further, the said surety or insurance company shall be duly licensed and qualified to do business in the State of Florida. **Bid bonds and performance and payment bonds are required. Insurance is required for all bids.**

In order to perform public work, the successful Bidder shall, as applicable, hold or obtain such Contractor' and Business Licenses as required by State Statutes.