



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

December 1, 2015

ADDENDUM #1, Bid L-08-16 – 8” Automatic Dry Priming ByPass Pump and Trailer (Rebid)

To Whom It May Concern,

Please review the following questions submitted by potential bidders, and answers from the City.

Q1: Please provide clarification for Item no. 4 of the specification. The stated pump operating conditions appears to be incorrect. It’s hydraulically impossible for a pump to meet both 300 GPM @ 50’ TDH and 1000 GPM @ 110’ TDH.

Response: Section I. Detail Specifications item 4 on page 3 of the bid document has been changed to reflect the correct GPM of 3,000 GPM @ 50’ TDH as shown below.

4. Pump shall be capable of producing 3,700 GPM @ 20’ of TDH, 3,000 GPM @ 50’ TDH, and 1,000 GPM @ 110’ TDH with five feet of suction lift with an engine speed of 2,000 RPM.

Addendum #1 is posted on the City’s website: <http://www.pompanobeachfl.gov>. Acknowledge receipt of this Addendum in the area provided on page 10 of the bid.

The deadline for acceptance of bids in the Purchasing Office, 1190 N.E. 3rd Avenue, Bldg. C, Pompano Beach, 33060, is **2:00 p.m. (local), December 16, 2015.**

The remainder of the solicitation is unchanged at this time.

Sincerely,

Cassandra LeMasurier, Purchasing Supervisor