



GENERAL NOTES:

1. ALL NONMETALLIC PIPE SHALL BE INSTALLED WITH 12 THHN SOLID COPPER TRACING WIRE.
2. THE MARKER BALLS MUST BE INSTALLED DIRECTLY ABOVE THE PIPE.
3. MARKER BALLS SHALL BE INSTALLED AT 40' O.C.
4. BALL COLOR CODING:
REUSE WATER SYSTEM: PURPLE

UTILITY PIPE AND MARKER BALLS LOCATION

ENGINEERING STANDARDS 2015

REVISIONS		ENGINEERING DIVISION CITY OF POMPANO BEACH	MARKER BALLS LOCATIONS	
BY	DATE			
TCW	09/07		DATE: MAY 2007	
			DWG. NO.	
		SCALE: N.T.S.	512-1	