



BOX
CDR WB 00-1118-12
LID
CDR WC 00-1118-02 GS

MINIMUM PIPE SLOPE 1/8" PER FOOT (USE GREATER WHERE POSSIBLE) MAXIMUM PIPE LENGTHS TO BE 12'-6"

*COORDINATE LOCATION & DEPTH WITH ENGINEER IN FIELD

**TERMINATE CLEAN-OUTS AT GRADE FOR IMPROVED PROPERTIES AND 3'-0" ABOVE GRADE FOR IMPROVED PROPERTIES

ALL PIPES AND FITTINGS SHALL BE GREEN 6" MIN. SDR 35

ENGINEERING STANDARDS 2015

REVISIONS		ENGINEERING DIVISION CITY OF POMPANO BEACH SCALE: N.T.S.	<h3 style="margin: 0;">SERVICE LATERALS</h3>	
BY	DATE		DATE: JUNE 1996 DWG. NO. <h2 style="margin: 0;">200-1</h2>	
S.S.	JUNE 2005			
T.W.	11-2007			
S.S.	01/27/12			
S.S.	07/10/12			