



GENERAL NOTES:

1. ALL NONMETALLIC PIPE SHALL BE INSTALLED WITH 12 THHN SOLID COPPER TRACING WIRE.
2. THE MARKER BALLS MUST BE INSTALLED DIRECTLY ABOVE THE PIPE.
3. MARKER BALLS SHALL BE INSTALLED AT 40' O.C.
4. BALL COLOR CODING:  
POTABLE WATER SYSTEM: BLUE

UTILITY PIPE AND MARKER BALLS LOCATION

**ENGINEERING STANDARDS 2015**

REVISIONS		ENGINEERING DIVISION CITY OF POMPANO BEACH	<b>UTILITY PIPE AND MARKER BALLS LOCATION</b>	
BY	DATE			
S.S.	01/12		DATE: JAN. 2012	
			DWG. NO.	
		SCALE: N.T.S.	<b>120-1</b>	